



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206 **Lab# 121**
(412) 661- 7665
Laboratory Analysis Report

CustomerFacility Name: *Hampton Inn*Address: *301 West Waterfront Dr.
Pittsburgh, PA 15120*Matrix: *Recreational Water*Source Type: *Pool***Sample Collection**Date: *11/17/25*Time: *1:30 PM*Method: *Grab***Sample Final Analysis**Date: *11/20/25*Time: *10:00 AM*Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/18/25	9:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	11/18/25	9:30 AM	SL SM 9222B
Standard plate count:	150/ml	200/ml	11/17/25	4:00 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/17/25	1:30 PM	DS DPD
Chlorine:	1.6 mg/l	1.0 - 5.0 mg/l	11/17/25	1:30 PM	DS DPD
Turbidity:	1 NTU	1 - 2 NTU	11/17/25	1:30 PM	DS Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor