



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2054

Customer

Facility Name: Bower Hill Swim Club
Address: 1600 Bower Hill Road
Pittsburgh, PA 15243

Matrix: Recreational Water
Source Type: Wading Pool

Sample Collection

Date: 7/7/25
Time: 12:24 PM
Method: Grab

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25 12:24 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25 12:24 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 12:24 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2054

Customer

Facility Name: Bower Hill Swim Club
Address: 1600 Bower Hill Road
Pittsburgh, PA 15243

Matrix: Recreational Water
Source Type: Wading Pool

Sample Collection

Date: 7/7/25
Time: 12:24 PM
Method: Grab

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25 12:24 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25 12:24 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 12:24 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor