Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 466

B & R Pools and Swim Shop

Customer

Facility Name:	*Towers Pool*
Address:	*1206 Bluff St.*
	Pittsburgh, PA 15282
Matrix:	*Recreational Water*
Source Type:	*Pool Shallow*

Sample Collection

Date:	*8/5/25*
Time:	1:10 PM
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	1:10 PM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:10 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:10 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab#   466

Customer

Facility Name:	*Towers Pool*
Address:	*1206 Bluff St.*
	Pittsburgh, PA 15282
Matrix:	*Recreational Water*
Source Type:	*Pool Shallow*

Sample Collection

Date:	*8/5/25*
Time:	*1:10 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	1:10 PM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:10 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:10 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor