



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 460

Customer

Facility Name: Wilmerding Center
Address: 1 Memorial Field
Wilmerding, PA 15148

Sample Collection

Date: 6/25/25
Time: 10:10 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/27/25
Time: 4:30 PM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	10:10 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/25/25	10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	10:10 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 460

Customer

Facility Name: Wilmerding Center
Address: 1 Memorial Field
Wilmerding, PA 15148

Sample Collection

Date: 6/25/25
Time: 10:10 AM
Method: Grab

Sample Final Analysis

Date: 6/27/25
Time: 4:30 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	10:10 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/25/25	10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	10:10 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor