Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 2162

Customer		*Sample Collection*	
Facility Name:	*Economy Park*	*Date:*	7/22/25
		Time:	1:00 PM
Address:	*5 Forcey Dr*	*Method:*	*Grab*
	Baden, PA 15005		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	7/25/25
		Time:	10:00 AM
Source Type:	*Pool*	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:00 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:00 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Lab# 2162

Customer

Facility Name:	*Economy Park*
Address:	*5 Forcey Dr*
	Baden, PA 15005
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/22/25*
Time:	*1:00 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*7/25/25*
Time:	*10:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:00 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:00 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor