



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Pennwood Square*

Address: *601 A Hay St*
Pittsburgh, PA 15221

Sample Collection

Date: *8/4/25*
Time: *11:40 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *8/7/25*
Time: *11:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	11:40 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/25	11:40 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:40 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Pennwood Square*

Address: *601 A Hay St*
Pittsburgh, PA 15221

Sample Collection

Date: *8/4/25*
Time: *11:40 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *8/7/25*
Time: *11:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	11:40 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/25	11:40 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:40 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor