



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2739

Customer

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spray Pad

Sample Collection

Date: 7/30/25

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	2:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	2:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	3:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/30/25	9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/30/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2739

Customer

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spray Pad

Sample Collection

Date: 7/30/25

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25 2:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25 2:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25 3:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/30/25 9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/30/25 9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25 9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor