



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 287

Customer

Facility Name: Spring Hill Suites Mt Lebanon

Address: 611 Washington Rd.
Pittsburgh, PA 15228

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/28/26

Time: 10:23 AM

Method: Grab

Sample Final Analysis

Date: 1/31/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	12:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/28/26	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	1/28/26	10:23 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/28/26	10:23 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/28/26	10:23 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor