



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

N-15

Lab# 167

Customer

Facility Name: Home 2 Suites
Address: 1401 Cranberry Woods Dr.
Cranberry, PA 16066
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/29/25
Time: 11:15 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:15 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:15 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:15 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

N-15

Lab# 167

Customer

Facility Name: Home 2 Suites
Address: 1401 Cranberry Woods Dr.
Cranberry, PA 16066
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/29/25
Time: 11:15 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:15 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:15 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:15 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor