Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2319

Customer		*Sample Collection*	
Facility Name:	*Liberty Hills*	*Date:*	*7/21/25*
		Time:	*12:21 PM*
Address:	*100 Liberty Lane*	*Method:*	*Grab*
	Freedom, PA 15042		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/24/25*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:53 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	12:21 PM	ZR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/21/25	12:21 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:21 PM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2319

Customer		*Sample Collection*	
Facility Name:	*Liberty Hills*	*Date:*	*7/21/25*
		Time:	*12:21 PM*
Address:	*100 Liberty Lane*	*Method:*	*Grab*
	Freedom, PA 15042		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/24/25*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:53 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	12:21 PM	ZR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/21/25	12:21 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:21 PM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)