



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

S-1

Lab# 193

**Customer**

Facility Name: Keystone Oaks High School

Address: 1000 Kelton Ave.  
Pittsburgh, PA 15216

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 10/28/25

Time: 11:14 AM

Method: Grab

**Sample Final Analysis**

Date: 10/31/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	10/29/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	10/28/25	11:14 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/28/25	11:14 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/25	11:14 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor