



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 232**

**Customer**

Facility Name: Moon Area High School

Address: 8353 University Blvd.  
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 11/10/25

Time: 9:43 AM

Method: Grab

**Sample Final Analysis**

Date: 11/13/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/25	9:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25	9:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/10/25	9:43 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/10/25	9:43 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/25	9:43 AM	AMH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)