



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2247

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Hickory Heights	Date:	6/9/25
Address:	118 Hickory Heights Dr. Bridgeville, PA 15017	Time:	12:42 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<u>Sample Final Analysis</u>	
Matrix:	Recreational Water	Date:	6/12/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:42 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:42 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:42 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2247

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Hickory Heights	Date:	6/9/25
Address:	118 Hickory Heights Dr. Bridgeville, PA 15017	Time:	12:42 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

<u>Accredited Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Incubation Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	SL	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:42 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:42 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:42 PM	AF	Visual

Sample comments

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor