



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

LCP

Lab# 2401

Customer

Facility Name: Pgh Golf Club
Address: 5280 Northumberland St.
Pittsburgh, PA 15217

Sample Collection

Date: 9/2/25
Time: 9:33 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/5/25
Time: 10:00 AM
Analyst: AS

Source Type: Pool - Deep

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	10:30 AM	SL	SM 9222B
Standard plate count:	60/ml	200/ml	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/2/25	9:33 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/2/25	9:33 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	9:33 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor