



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2671

Customer

Facility Name: Summer Seat
Address: 114 Gateway Dr.
Pittsburgh, PA 15237

Sample Collection

Date: 8/26/25
Time: 11:56 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 8/29/25
Time: 10:30 AM
Analyst: 1/0/00

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|-----------------------|----------|----------|---------|----------|----|----------|
| Escherichia Coli: | Absent | Absent | 8/27/25 | 12:00 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/27/25 | 12:00 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/26/25 | 6:00 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|---------------------|----------|----------|---------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/27/25 | 12:10 PM | PS | SM 9230C |
|---------------------|----------|----------|---------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | | |
|------------|----------|----------------|---------|----------|----|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/26/25 | 11:56 AM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/26/25 | 11:56 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/26/25 | 11:56 AM | MM | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor