



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 2635

Customer

Facility Name: Village Cranberry Woods Apt.

Address: 5001 Pendleton Way
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/29/25

Time: 10:50 AM

Method: Grab

Sample Final Analysis

Date: 10/2/25

Time: 11:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/30/25 | 10:30 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/30/25 | 10:30 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/29/25 | 5:40 PM | SL | SM 9215B |
| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/30/25 | 12:00 AM | SL | SM 9230C |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/29/25 | 10:50 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/29/25 | 10:50 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/29/25 | 10:50 AM | BH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor