



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2700

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Hamilton Place

Date: 7/22/25

Address: 100 Addie Ct.
Pittsburgh, PA 15234

Time: 1:47 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Source Type: Pool

Date: 7/25/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:47 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:47 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:47 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2700

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Hamilton Place*

Address: *100 Addie Ct.*
 Pittsburgh, PA 15234

Sample Collection

Date: *7/22/25*
Time: *1:47 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *7/25/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:47 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:47 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:47 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor