



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2500**

**Customer**

Facility Name: Southwind

Address: 777 Waterwheel Dr.  
Champion, PA 15622

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 7/21/25

Time: 11:43 AM

Seven Spring Method: Grab

**Sample Final Analysis**

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/22/25	12:30 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	11:43 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:43 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:43 AM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2500**

**Customer**

**Facility Name:** Southwind  
**Address:** 777 Waterwheel Dr.  
Champion, PA 15622

**Sample Collection**

**Date:** 7/21/25  
**Time:** 11:43 AM  
**Method:** Grab

**Sample Final Analysis**

**Matrix:** Recreational Water  
**Date:** 7/24/25  
**Time:** 10:00 AM  
**Source Type:** Spa  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/22/25	12:30 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	11:43 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:43 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:43 AM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor