



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2365

Customer

Facility Name: Mountain Pines Campground

Address: 1662 Indian Creek Valley Rd.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Pool- indoor

Sample Collection

Date: 6/24/25

Time: 12:07 PM

Method: Grab

Sample Final Analysis

Date: 6/27/25

Time: 9:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	12:07 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:07 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:07 PM	JC	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2365

Customer

Facility Name: *Mountain Pines Campground*

Address: *1662 Indian Creek Valley Rd.
Champion, PA 15622*

Matrix: *Recreational Water*

Source Type: *Pool- indoor*

Sample Collection

Date: *6/24/25*

Time: *12:07 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/27/25*

Time: *9:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	12:07 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:07 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:07 PM	JC	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor