

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2171

Sample Final Analysis

Sample Collection **Customer**

Facility Name: Edgewood Club Date: 6/23/25 Time: 1:28 PM 1 Pennwood Ave Address: Method: Grab

Pittsburgh, PA 15218

Recreational Water Matrix: Date: 6/26/25

Time: 9:00 AM Source Type: Baby Pool AS Analyst:

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/24/25 9:15 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/24/25 9:15 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 3:03 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	1:28 PM	EH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:28 PM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:28 PM	EH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2171

Sample Final Analysis

Sample Collection **Customer**

Facility Name: Edgewood Club Date: 6/23/25 Time: 1:28 PM 1 Pennwood Ave Address: Method: Grab

Pittsburgh, PA 15218

Matrix: Recreational Water Date: 6/26/25

Time: 9:00 AM Source Type: Baby Pool AS Analyst:

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/24/25 9:15 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/24/25 9:15 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 3:03 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	1:28 PM	EH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:28 PM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:28 PM	EH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor