Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# **176**

Customer		_Sample Collection_	
Facility Name:	*Hyatt House- Bloomfield*	*Date:*	*6/9/25*
		Time:	12:50 PM
Address:	*5335 Baum Blvd.*	*Method:*	*Grab*
	Pittsburgh, Pa 15224		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/12/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	3:10 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:50 PM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:50 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:50 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 176

Customer

Facility Name:	*Hyatt House- Bloomfield*
Address:	*5335 Baum Blvd.* *Pittsburgh, Pa 15224*
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/9/25*
Time:	12:50 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/12/25*
Time:	*9:30 AM*
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	3:10 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:50 PM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:50 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:50 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith