



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2063

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Brook Park Swim Club*
Address: *8190 Rochester Rd*
Pittsburgh, PA 15237

Date: 8/5/25
Time: 1:24 PM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Shallow End*

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	3:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	3:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	1:24 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:24 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:24 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2063

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Brook Park Swim Club*

Address: *8190 Rochester Rd*
Pittsburgh, PA 15237

Date: 8/5/25
Time: 1:24 PM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Shallow End*

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	3:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	3:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	1:24 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:24 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:24 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor