



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 313****Customer****Facility Name:** UPMC Sports Rehab - Cranberry**Address:** 8000 Cranberry Springs Drive
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Spa**Sample Collection****Date:** 2/10/26**Time:** 10:30 AM**Method:** Grab**Sample Final Analysis****Date:** 2/13/26**Time:** 10:30 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/11/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/11/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/10/26	5:30 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/11/26	10:20 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	2/10/26	10:30 AM	RD	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/10/26	10:30 AM	RD	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/10/26	10:30 AM	RD	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)