

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2240

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Hampshire House Apt

Address: 195 Mt. Lebanon Blvd.

Pittsburgh, PA 15228

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 6/17/25

 Time:
 4:40 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis	Results Reporting lim	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/18/25	11:35 AM	АН	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/18/25	11:35 AM	АН	SM 9222B	
Standard plate count:	0/ml	200/ml	6/17/25	5:45 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	6/17/25	4:40 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/17/25	4:40 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	4:40 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2240

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Hampshire House Apt

Address: 195 Mt. Lebanon Blvd.

Pittsburgh, PA 15228

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 6/17/25

 Time:
 4:40 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis	Results Reporting lim	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/18/25	11:35 AM	АН	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/18/25	11:35 AM	АН	SM 9222B	
Standard plate count:	0/ml	200/ml	6/17/25	5:45 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	6/17/25	4:40 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/17/25	4:40 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	4:40 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor