

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E-2

Lab ID No. 02-04041

Lab# 233

Customer

Facility Name:

Mt. Pleasant High School

Address:

265 State St.

Mt Pleasant, PA 15666

Matrix:

Recreational Water

Source Type: Pool Sample Collection

Date:

9/2/25 9:30 AM

Time: Method:

Grab

Sample Final Analysis

Date:

9/5/25 10:00 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	t Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/2/25	9:30 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/2/25	9:30 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	9:30 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor