

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 429

Customer

Facility Name: Upper St. Clair High School

Address: 1825 McLaughlin Run Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Lap Shallow Sample Collection

7/14/25 Date:

Time: 3:14 PM Method: Grab

Sample Final Analysis

Date: 7/17/25 Time: 8:30 AM

Analyst: AS

Accredited Analysis Escherichia Coli:	Absent Absent	Absent	Incubation Date/Time		Analyst	Method
			7/15/25	10:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/14/25	3:14 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:14 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:14 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 429

Customer

Facility Name: Upper St. Clair High School

Address: 1825 McLaughlin Run Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Lap Shallow Sample Collection

7/14/25 Date:

Time: 3:14 PM Method: Grab

Sample Final Analysis

Date: 7/17/25 Time: 8:30 AM

Analyst: AS

Accredited Analysis Escherichia Coli:	Absent Absent	Absent	Incubation Date/Time		Analyst	Method
			7/15/25	10:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/14/25	3:14 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:14 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:14 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith