



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 158

Customer

Facility Name: *Holiday Inn Express*

Address: *181 Finley Rd.*
Belle Vernon, PA 15012

Sample Collection

Date: *12/29/25*
Time: *11:00 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *1/1/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/25	10:30 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	12/29/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	12/29/25	11:00 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/29/25	11:00 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/29/25	11:00 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)