

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2113

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Clinton Lake Sample Collection

Date: 6/17

 E:
 Clinton Lake
 Date:
 6/17/25

 Time:
 1:38 PM

 124 Clinton Dr.
 Method:
 Grab

Address: 124 Clinton Dr. Clinton, PA 15026

Matrix: Recreational Water Sample Final Analysis

Date: 6/20/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Da	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Results Reporting limit		Date/Time		Method
pH:	7.8 SU	7.2 - 7.8 SU	6/17/25	1:38 PM	АН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	1:38 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	1:38 PM	АН	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2113

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Clinton Lake Sample Collection

Date: 6/17

 E:
 Clinton Lake
 Date:
 6/17/25

 Time:
 1:38 PM

 124 Clinton Dr.
 Method:
 Grab

Address: 124 Clinton Dr. Clinton, PA 15026

Matrix: Recreational Water Sample Final Analysis

Date: 6/20/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Da	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Results Reporting limit		Date/Time		Method
pH:	7.8 SU	7.2 - 7.8 SU	6/17/25	1:38 PM	АН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	1:38 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	1:38 PM	АН	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor