



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2522

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Terrain Apts

**Sample Collection**

Date: 7/21/25

Time: 3:55 PM

Method: Grab

Address: 700 Mansfield Road  
Pittsburgh, PA, 15205

**Sample Final Analysis**

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	3:55 PM	CW DPD
Chlorine:	8.0 mg/l	1.0 - 5.0 mg/l	7/21/25	3:55 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	3:55 PM	CW Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2522

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Terrain Apts

**Sample Collection**

Date: 7/21/25

Time: 3:55 PM

Method: Grab

Address: 700 Mansfield Road  
Pittsburgh, PA, 15205

**Sample Final Analysis**

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	3:55 PM	CW DPD
Chlorine:	8.0 mg/l	1.0 - 5.0 mg/l	7/21/25	3:55 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	3:55 PM	CW Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor