**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

*Lab#  262*

## Customer

| | |
|---|---|
| *Facility Name:* | *Rehabilitation Institute* |
| *Address:* | *1405 Shady Ave.* |
| | *Pittsburgh, PA 15217* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool - Sm* |

## Sample Collection

| | |
|---|---|
| *Date:* | *6/2/25* |
| *Time:* | 9:05 AM |
| *Method:* | *Grab* |

## Sample Final Analysis

| | |
|---|---|
| *Date:* | *6/5/25* |
| *Time:* | *9:30 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 6/3/25 | 9:40 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/3/25 | 9:40 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/2/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8  SU | 7.2 - 7.8 SU | 6/2/25 | 9:05 AM | LM | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 9:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 9:05 AM | LM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

_Andre Smith_

---
Andre Smith, Lead Supervisor

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**C-10**

*Lab#  262*

---

*Customer*

| | |
|---|---|
| *Facility Name:* | *Rehabilitation Institute* |
| *Address:* | *1405 Shady Ave.* |
| | *Pittsburgh, PA 15217* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool - Sm* |

*Sample Collection*

| | |
|---|---|
| *Date:* | *6/2/25* |
| *Time:* | 9:05 AM |
| *Method:* | *Grab* |

*Sample Final Analysis*

| | |
|---|---|
| *Date:* | *6/5/25* |
| *Time:* | *9:30 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 6/3/25 | 9:40 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/3/25 | 9:40 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/2/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8  SU | 7.2 - 7.8 SU | 6/2/25 | 9:05 AM | LM | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 9:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 9:05 AM | LM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor