Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2044

Customer

Facility Name:	*Blackridge Swim Club*
Address:	*1200 Beulah Rd*
	Pittsburgh, PA 15221
Matrix:	*Recreational Water*
Source Type:	*Baby Pool*

Sample Collection

Date:	*7/14/25*
Time:	12:00 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/17/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	11:15 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:15 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:15 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab#   2044

B & R Pools and Swim Shop

Customer		*Sample Collection*	
Facility Name:	*Blackridge Swim Club*	*Date:*	7/14/25
		Time:	12:00 AM
Address:	*1200 Beulah Rd*	*Method:*	*Grab*
	Pittsburgh, PA 15221		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	7/17/25
		Time:	8:30 AM
Source Type:	*Baby Pool*	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	11:15 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:15 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:15 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor