

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 221

<u>Custome</u>r Sample Collection Masonic Village Date: Facility Name: 5/28/25 Time: 11:15 AM 1000 Masonic Dr. Method: Grab Address: Sewickley, PA 15143 Sample Final Analysis Matrix: Recreational Water Date: 5/31/25 9:30 AM Time: Source Type: AS Analyst: Spa **Accredited Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** SM 9222G Escherichia Coli: Absent Absent 5/29/25 9:30 AM SL Total coliforms: 0/100mls 2/100mls 9:30 AM SL SM 9222B 5/29/25

Standard plate count: 0/ml 200/ml 5/28/25 3:25 PM AH SM 9215B

Additional Analysis Results Reporting limit Incubation Date/Time Analyst Method

Fecal Streptococcus 0/100mls 2/100mls 5/29/25 11:30 AM AH SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	11:15 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:15 AM	VH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 221

<u>Custome</u>r Sample Collection Masonic Village Date: Facility Name: 5/28/25 Time: 11:15 AM 1000 Masonic Dr. Method: Grab Address: Sewickley, PA 15143 Sample Final Analysis Matrix: Recreational Water Date: 5/31/25 9:30 AM Time: Source Type: AS Analyst: Spa **Accredited Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** SM 9222G Escherichia Coli: Absent Absent 5/29/25 9:30 AM SL Total coliforms: 0/100mls 2/100mls 9:30 AM SL SM 9222B 5/29/25

Standard plate count: 0/ml 200/ml 5/28/25 3:25 PM AH SM 9215B

Additional Analysis Results Reporting limit Incubation Date/Time Analyst Method

Fecal Streptococcus 0/100mls 2/100mls 5/29/25 11:30 AM AH SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	11:15 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:15 AM	VH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor