



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 314**

**Customer**

Facility Name: UPMC Sports Rehab - South

Address: 3200 S. Water St  
Pittsburgh, PA 15203

Matrix: Recreational Water

Source Type: Therapy Spa

**Sample Collection**

Date: 6/30/25

Time: 10:45 AM

Method: Grab

**Sample Final Analysis**

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/1/25	10:00 AM	EB	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/1/25	10:00 AM	EB	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:45 AM	DS	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	1.8 mg/l	1.0 - 5.0 mg/l	6/30/25	10:45 AM	DS	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:45 AM	DS	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 314**

**Customer**

Facility Name: UPMC Sports Rehab - South

Address: 3200 S. Water St  
Pittsburgh, PA 15203

Matrix: Recreational Water

Source Type: Therapy Spa

**Sample Collection**

Date: 6/30/25

Time: 10:45 AM

Method: Grab

**Sample Final Analysis**

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/1/25	10:00 AM	EB	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/1/25	10:00 AM	EB	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:45 AM	DS	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	1.8 mg/l	1.0 - 5.0 mg/l	6/30/25	10:45 AM	DS	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:45 AM	DS	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor