



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 044**

**Customer**

**Facility Name:** Carnegie Mellon  
**Address:** 5000 Forbes Ave.  
Pittsburgh, PA 15213

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/30/25  
**Time:** 10:20 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/3/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G

Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
------------------	----------	----------	--------	---------	----	----------

Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	AH	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:20 AM	LM	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:20 AM	LM	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:20 AM	LM	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 044**

**Customer**

**Facility Name:** Carnegie Mellon  
**Address:** 5000 Forbes Ave.  
Pittsburgh, PA 15213

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/30/25  
**Time:** 10:20 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/3/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G

Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
------------------	----------	----------	--------	---------	----	----------

Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	AH	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:20 AM	LM	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:20 AM	LM	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:20 AM	LM	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor