Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

C-10

Lab# 306

Customer		*Sample Collection*	
Facility Name:	*University of Pittsburgh*	*Date:*	*7/28/25*
		Time:	11:50 AM
Address:	*3501 Allequippa St.*	*Method:*	*Grab*
	Pittsburgh, PA 15260		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/31/25*
		Time:	*9:00 AM*
Source Type:	*Sm Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/28/25	11:50 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

C-10

Lab# **306**

Customer

Facility Name:	*University of Pittsburgh*
Address:	*3501 Allequippa St.* *Pittsburgh, PA 15260*
Matrix:	*Recreational Water*
Source Type:	*Sm Pool Deep*

Sample Collection

Date:	*7/28/25*
Time:	11:50 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/31/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/28/25	11:50 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor