



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-2**

**Lab# 386**

**Customer**

Facility Name: *Residence Inn Cranberry*

Address: *1308 Freedom RDd.  
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *9/3/25*

Time: *12:45 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *9/6/25*

Time: *2:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	9:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	9:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/3/25	12:45 PM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/3/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/25	12:45 PM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor