



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2642

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Heritage Hills* *Date:* *8/25/25*
Address: *1250 Village Green Dr.* *Time:* *11:50 AM*
Jefferson Hills, PA 15025 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *8/28/25*
Source Type: *Pool* *Time:* *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25 8:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25 8:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25 3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/25/25 11:50 AM	BL	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/25/25 11:50 AM	BL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25 11:50 AM	BL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor