

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2002

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Eastside Bond

Address: 6015 Spirit St.

Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/25 Time: 8:35 AM

Method: Grab

Sample Final Analysis

 Date:
 7/31/25

 Time:
 9:00 AM

Analyst: AS

n Date/Time Analyst Metho

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	8:35 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	8:35 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	8:35 AM	LM	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2002

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Eastside Bond

Address: 6015 Spirit St.

Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/25 Time: 8:35 AM

Method: Grab

Sample Final Analysis

 Date:
 7/31/25

 Time:
 9:00 AM

Analyst: AS

n Date/Time Analyst Metho

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	8:35 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	8:35 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	8:35 AM	LM	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor