



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2388

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Oxford Athletic	Date:	6/16/25			
Address:	100 Village Club Dr. Wexford, PA 15090	Time:	2:33 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	6/19/25			
	Spray Pad	Time:	10:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	2:33 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:33 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:33 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2388

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Oxford Athletic	Date:	6/16/25			
Address:	100 Village Club Dr. Wexford, PA 15090	Time:	2:33 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	6/19/25			
	Spray Pad	Time:	10:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	2:33 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:33 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:33 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor