

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3** 

Lab# 2451

American Pools Management Customer

> 3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Rose Garden

Address: 129 Canterbury Ln.

Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

Escherichia Coli:

Sample Collection

7/22/25 Date:

Time: 10:38 AM Method: Grab

Sample Final Analysis

7/25/25 Date:

10:00 AM Time: AS Analyst:

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method 7/23/25 AΗ Absent Absent 12:00 PM SM 9222G

Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B

Standard plate count: 0/ml200/ml 7/22/25 6:00 PM SL SM 9215B

**Additional Analysis** Results **Reporting limit Incubation Date/Time Analyst** Method pH: 7.4 SU 7.2 - 7.8 SU 7/22/25 10:38 AM ΑF DPD Chlorine: 2.0 mg/l 1.0 - 5.0 mg/l 7/22/25 10:38 AM AF DPD 1 - 2 NTU 7/22/25 AF Turbidity: 1 NTU 10:38 AM Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3** 

Lab# 2451

American Pools Management Customer

> 3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Rose Garden

Address: 129 Canterbury Ln.

Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

Escherichia Coli:

Sample Collection

7/22/25 Date:

Time: 10:38 AM Method: Grab

Sample Final Analysis

7/25/25 Date:

10:00 AM Time: AS Analyst:

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method 7/23/25 AΗ Absent Absent 12:00 PM SM 9222G

Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B

Standard plate count: 0/ml200/ml 7/22/25 6:00 PM SL SM 9215B

**Additional Analysis** Results **Reporting limit Incubation Date/Time Analyst** Method pH: 7.4 SU 7.2 - 7.8 SU 7/22/25 10:38 AM ΑF DPD Chlorine: 2.0 mg/l 1.0 - 5.0 mg/l 7/22/25 10:38 AM AF DPD 1 - 2 NTU 7/22/25 AF Turbidity: 1 NTU 10:38 AM Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor