



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

C-2

Lab# 279

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Sheraton Inn	Date:	10/28/25			
Address:	300 W Station Sq. Dr. Pittsburgh, PA 15219	Time:	2:05 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	10/31/25			
		Time:	10:30 AM			
Source Type:	Pool	Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	10/29/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	10/28/25	2:05 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/28/25	2:05 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/25	2:05 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor