



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 164**

**Customer**

**Facility Name:** *Holiday Inn Express - Butler*

**Address:** *203 North Duffy Rd  
Butler, PA 16001*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *11/24/25*

**Time:** *3:10 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *11/27/25*

**Time:** *12:30 PM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/24/25	3:10 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	11/24/25	3:10 PM	BH	DPD
Turbidity:	2 NTU	1 - 2 NTU	11/24/25	3:10 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor