

Matrix:

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 461

Customer Sample Collection

Facility Name: Holiday Inn Date: 5/27/25

Address: Time: 12:40 PM
Address: 105 Stone Quarry Rd. Method: Grab

105 Stone Quarry Rd. Method:
Monaca, PA 15061

Sample Final Analysis

Recreational Water Date: 5/30/25
Time: 9:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	ing limit Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	12:40 PM	АН	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:40 PM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:40 PM	АН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Matrix:

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 461

Customer Sample Collection

Facility Name: Holiday Inn Date: 5/27/25

Address: Time: 12:40 PM
Address: 105 Stone Quarry Rd. Method: Grab

105 Stone Quarry Rd. Method:
Monaca, PA 15061

Sample Final Analysis

Recreational Water Date: 5/30/25
Time: 9:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	ing limit Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	12:40 PM	АН	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:40 PM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:40 PM	АН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor