



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 497

Customer

Facility Name: Park Inn
Address: 1924 Leesburg Grove City Road
Grove City, PA, 16127

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/2/25
Time: 1:00 PM
Method: Grab

Sample Final Analysis

Date: 12/5/25
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/25	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/25	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	12/2/25	1:00 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/2/25	1:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/25	1:00 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor