



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2252

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>
Facility Name:	Hidden Valley Manor	Date: 8/11/25
Address:	2774 Bingham Dr. Upper St. Clair, PA 15241	Time: 2:58 PM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Pool	Date: 8/14/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	2:58 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:58 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:58 PM	AF	Visual

Sample comments

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2252

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>
Facility Name:	Hidden Valley Manor	Date: 8/11/25
Address:	2774 Bingham Dr. Upper St. Clair, PA 15241	Time: 2:58 PM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Pool	Date: 8/14/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	2:58 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:58 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:58 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor