



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2089

Customer

Facility Name: Chanticleer Swim Club

Address: 1032 Chanticleer Drive
Crescent, PA 15046

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/21/25

Time: 10:36 AM

Method: Grab

Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/22/25 | 12:00 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/22/25 | 12:00 PM | SL | SM 9222B |
| Standard plate count: | 200/ml | 200/ml | 7/21/25 | 6:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/21/25 | 10:36 AM | AH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/21/25 | 10:36 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/21/25 | 10:36 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2089

Customer

Facility Name: Chanticleer Swim Club

Address: 1032 Chanticleer Drive
Crescent, PA 15046

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/21/25

Time: 10:36 AM

Method: Grab

Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/22/25 | 12:00 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/22/25 | 12:00 PM | SL | SM 9222B |
| Standard plate count: | 200/ml | 200/ml | 7/21/25 | 6:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/21/25 | 10:36 AM | AH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/21/25 | 10:36 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/21/25 | 10:36 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor