



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 364**

**Customer**

**Facility Name:** YMCA - Sewickley  
**Address:** 625 Blackburn Rd.  
Sewickley, PA 15143

**Matrix:** Recreational Water

**Source Type:** Small Pool

**Sample Collection**

**Date:** 12/9/25  
**Time:** 4:17 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/12/25  
**Time:** 11:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/9/25	4:17 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/9/25	4:17 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/25	4:17 PM	SL	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)