

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

S-10

Lab# 2473

Customer Facility Name:

Scott Twp.

Address:

301 Lindsay Road

Carnegie, PA 15106

Matrix:

Recreational Water

Source Type:

Shallow End

Sample Collection

7/28/25 Date: Time:

11:58 AM Method: Grab

Sample Final Analysis

Date:

Time:

7/31/25 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:58 AM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:58 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:58 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

S-10

Lab# 2473

Customer Facility Name:

Scott Twp.

Address:

301 Lindsay Road

Carnegie, PA 15106

Matrix:

Recreational Water

Source Type:

Shallow End

Sample Collection

7/28/25 Date: Time:

11:58 AM Method: Grab

Sample Final Analysis

Date:

Time:

7/31/25 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:58 AM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:58 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:58 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor