



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 2202**

**Customer**

**Facility Name:** Fox Chapel Golf Club  
**Address:** 426 Fox Chapel Road  
Pittsburgh, PA 15238-2298

**Matrix:** Recreational Water

**Source Type:** Baby Pool

**Sample Collection**

**Date:** 8/12/25  
**Time:** 12:35 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/13/25              | 10:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/13/25              | 10:30 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/12/25              | 4:25 PM  | EB      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 8/12/25   | 12:35 PM | BH      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 8/12/25   | 12:35 PM | BH      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 8/12/25   | 12:35 PM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 2202**

**Customer**

**Facility Name:** Fox Chapel Golf Club  
**Address:** 426 Fox Chapel Road  
Pittsburgh, PA 15238-2298

**Matrix:** Recreational Water

**Source Type:** Baby Pool

**Sample Collection**

**Date:** 8/12/25  
**Time:** 12:35 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/13/25              | 10:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/13/25              | 10:30 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/12/25              | 4:25 PM  | EB      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 8/12/25   | 12:35 PM | BH      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 8/12/25   | 12:35 PM | BH      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 8/12/25   | 12:35 PM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor