

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2063

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/30/25

Time: 12:21 PM Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 3:30 PM Analyst: AS

Accredited Analysis Results **Reporting limit** Analyst Method **Incubation Date/Time** 7/30/25 5:30 PM SL Escherichia Coli: Absent Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/30/25 5:30 PM SL SM 9222B Standard plate count: 180/ml 200/ml 7/30/25 4:50 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/30/25	12:21 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/30/25	12:21 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:21 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2063

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/30/25

Time: 12:21 PM Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 3:30 PM Analyst: AS

Accredited Analysis Results **Reporting limit** Analyst Method **Incubation Date/Time** 7/30/25 5:30 PM SL Escherichia Coli: Absent Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/30/25 5:30 PM SL SM 9222B Standard plate count: 180/ml 200/ml 7/30/25 4:50 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/30/25	12:21 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/30/25	12:21 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:21 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor